


QL19.04: Minimal 10 cámaras - Wide Flood - LED - Negro



QL19 04 ES 1 / 2

Coefficientes de uso

R	77	75	73	71	55	53	33	00	DRR
K0.8	75	71	68	66	70	68	68	65	78
1.0	78	75	72	70	74	72	71	69	83
1.5	82	79	77	76	79	77	76	74	89
2.0	85	83	81	80	82	80	79	77	93
2.5	86	85	84	83	84	83	82	79	96
3.0	87	86	85	85	85	84	83	81	98
4.0	88	87	87	86	86	86	84	82	99
5.0	89	88	88	88	87	86	85	83	100

Diagrama UGR

Corrected UGR values (at 1700 lm bare lamp luminous flux)											
Reflect.:		viewed crosswise					viewed endwise				
ceiling/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim		viewed crosswise					viewed endwise				
x	y										
2H	2H	1.4	1.9	1.7	2.1	2.4	1.4	1.9	1.7	2.1	2.4
	3H	1.3	1.7	1.6	2.0	2.3	1.3	1.7	1.6	2.0	2.3
	4H	1.2	1.6	1.5	1.9	2.2	1.2	1.6	1.5	1.9	2.2
	6H	1.1	1.5	1.5	1.8	2.2	1.1	1.5	1.5	1.8	2.2
	8H	1.1	1.5	1.5	1.8	2.1	1.1	1.5	1.5	1.8	2.1
	12H	1.1	1.4	1.4	1.8	2.1	1.1	1.4	1.4	1.8	2.1
4H	2H	1.2	1.6	1.5	1.9	2.2	1.2	1.6	1.5	1.9	2.2
	3H	1.1	1.4	1.4	1.8	2.1	1.1	1.4	1.4	1.8	2.1
	4H	1.0	1.3	1.4	1.7	2.0	1.0	1.3	1.4	1.7	2.0
	6H	0.9	1.2	1.3	1.6	2.0	0.9	1.2	1.3	1.6	2.0
	8H	0.9	1.1	1.3	1.5	1.9	0.8	1.1	1.3	1.5	1.9
	12H	0.8	1.0	1.3	1.5	1.9	0.8	1.0	1.2	1.4	1.9
8H	4H	0.8	1.1	1.3	1.5	1.9	0.9	1.1	1.3	1.5	1.9
	6H	0.8	1.0	1.2	1.4	1.9	0.8	1.0	1.2	1.4	1.9
	8H	0.7	0.9	1.2	1.3	1.8	0.7	0.9	1.2	1.3	1.8
	12H	0.6	0.8	1.2	1.3	1.8	0.6	0.8	1.1	1.3	1.8
12H	4H	0.8	1.0	1.2	1.4	1.9	0.8	1.0	1.3	1.5	1.9
	6H	0.7	0.9	1.2	1.3	1.8	0.7	0.9	1.2	1.3	1.8
	8H	0.6	0.8	1.1	1.3	1.8	0.6	0.8	1.2	1.3	1.8
Variations with the observer position at spacing:											
S =		0.9 / -18.0					0.9 / -18.0				
		9.7 / -18.3					9.7 / -18.3				
		11.7 / -18.4					11.7 / -18.4				