




# Coefficientes de uso

R	77	75	73	71	55	53	33	00	DRR
K0.8	63	60	58	56	59	57	57	55	78
1.0	66	63	61	59	62	60	60	58	83
1.5	69	67	65	64	66	65	64	62	89
2.0	71	70	69	67	69	68	67	65	93
2.5	73	71	71	70	71	70	69	67	96
3.0	74	73	72	71	72	71	70	68	98
4.0	74	74	73	73	73	72	71	70	99
5.0	75	74	74	74	73	73	72	70	100

## Curva límite de luminancia



## Diagrama UGR

Corrected UGR values (at 2250 lm bare lamp luminous flux)											
Reflect.:		viewed crosswise					viewed endwise				
ceiling	cav	0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim											
x	y										
2H	2H	5.1	5.5	5.3	5.8	6.0	5.3	5.7	5.5	6.0	6.2
	3H	4.9	5.4	5.2	5.6	5.9	5.1	5.6	5.4	5.8	6.1
	4H	4.9	5.3	5.2	5.5	5.8	5.1	5.5	5.4	5.8	6.0
	6H	4.8	5.2	5.1	5.5	5.8	5.0	5.4	5.3	5.7	6.0
	8H	4.8	5.1	5.1	5.4	5.8	5.0	5.3	5.3	5.6	6.0
	12H	4.7	5.1	5.1	5.4	5.7	4.9	5.3	5.3	5.6	5.9
4H	2H	4.9	5.3	5.2	5.6	5.8	5.1	5.5	5.4	5.8	6.0
	3H	4.7	5.1	5.1	5.4	5.7	4.9	5.3	5.3	5.6	5.9
	4H	4.6	4.9	5.0	5.3	5.7	4.8	5.1	5.2	5.5	5.9
	6H	4.5	4.8	5.0	5.2	5.6	4.7	5.0	5.2	5.4	5.8
	8H	4.5	4.7	4.9	5.1	5.6	4.7	4.9	5.1	5.3	5.8
	12H	4.4	4.7	4.9	5.1	5.5	4.6	4.9	5.1	5.3	5.7
8H	4H	4.5	4.7	4.9	5.1	5.6	4.7	4.9	5.1	5.3	5.8
	6H	4.4	4.6	4.9	5.0	5.5	4.6	4.8	5.1	5.2	5.7
	8H	4.3	4.5	4.8	5.0	5.5	4.5	4.7	5.0	5.2	5.7
	12H	4.3	4.4	4.8	4.9	5.4	4.5	4.6	5.0	5.1	5.6
12H	4H	4.4	4.7	4.9	5.1	5.5	4.6	4.9	5.1	5.3	5.7
	6H	4.3	4.5	4.8	5.0	5.5	4.5	4.7	5.0	5.2	5.7
	8H	4.3	4.4	4.8	4.9	5.4	4.5	4.6	5.0	5.1	5.6
Variations with the observer position at spacing:											
S =		1.0H	6.7 / -17.0				6.6 / -18.7				
		1.5H	9.5 / -23.9				9.5 / -27.2				
		2.0H	11.5 / -33.7				11.5 / -32.9				