


Last information update: May 2024

**Product configuration: MU27**

MU27: Square recess - warm white - electronic ballast - general light optic with controlled luminance UGR&lt;19

**Product code**MU27: Square recess - warm white - electronic ballast - general light optic with controlled luminance UGR<19 **Attention! Code no longer in production****Technical description**

Recessed fixed square luminaire designed to use a LED lamp. Version with rim for surface-mounting. Reflector vacuum-metallised with aluminium vapours with an anti-scratch protective layer. Die-cast aluminium body and passive dissipation system. Product complete with LED unit in a warm white tone 3,000K and electronic driver separate from the luminaire. General light distribution, with controlled luminance (UGR<19).

**Installation**


Recessed using torsion springs which allow easy installation in false ceilings with thickness ranging from 1 mm to 20 mm.

Colour	Weight (Kg)
White / Aluminium (39)	1


Mounting
ceiling recessed

Wiring
Product complete with electronic components

Complies with EN60598-1 and pertinent regulations

**Technical data**


Im system:	1759	CRI:	80
W system:	17	Colour temperature [K]:	3000
Im source:	2000	MacAdam Step:	3
W source:	14	Life Time LED 1:	50,000h - L80 - B10 (Ta 25°C)
Luminous efficiency (Im/W, real value):	103.5	Lamp code:	LED
Im in emergency mode:	-	Number of lamps for optical assembly:	1
Total light flux at or above an angle of 90° [Lm]:	0	ZVEI Code:	LED
Light Output Ratio (L.O.R.) [%]:	88	Number of optical assemblies:	1

**Polar**

### Utilisation factors

R	77	75	73	71	55	53	33	00	DRR
K0.8	77	72	69	66	71	68	68	64	73
1.0	81	76	73	71	75	73	72	69	79
1.5	86	82	80	78	81	79	78	75	86
2.0	89	86	84	83	85	83	82	80	91
2.5	90	89	87	86	87	86	85	82	94
3.0	92	90	89	88	89	88	87	84	96
4.0	93	92	91	90	90	89	88	86	98
5.0	93	93	92	91	91	90	89	87	99

### Luminance curve limit



### UGR diagram

Corrected UGR values (at 2000 lm bare lamp luminous flux)									
Reflect.:		viewed crosswise					viewed endwise		
ceil/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim		viewed crosswise					viewed endwise		
X	Y								
2H	2H	19.2	19.9	19.5	20.1	20.3	19.2	19.9	19.5
3H	19.1	19.7	19.4	19.9	20.2	19.1	19.7	19.4	19.9
4H	19.0	19.6	19.4	19.9	20.2	19.0	19.5	19.4	19.8
6H	19.0	19.4	19.3	19.8	20.1	18.9	19.4	19.3	19.7
8H	18.9	19.4	19.3	19.7	20.1	18.9	19.4	19.3	19.7
12H	18.9	19.3	19.3	19.7	20.0	18.9	19.3	19.2	19.7
4H	2H	19.0	19.6	19.4	19.9	20.2	19.0	19.5	19.4
3H	18.9	19.3	19.3	19.7	20.0	18.9	19.3	19.2	19.7
4H	18.8	19.2	19.2	19.5	19.9	18.8	19.2	19.2	19.5
6H	18.7	19.0	19.1	19.4	19.9	18.7	19.0	19.1	19.4
8H	18.7	19.0	19.1	19.4	19.8	18.6	19.0	19.1	19.4
12H	18.6	18.9	19.1	19.3	19.8	18.6	18.9	19.0	19.3
8H	4H	18.7	19.0	19.1	19.4	19.8	18.6	19.0	19.1
6H	18.6	18.8	19.0	19.3	19.7	18.6	18.8	19.0	19.3
8H	18.5	18.7	19.0	19.2	19.7	18.5	18.7	19.0	19.2
12H	18.5	18.7	19.0	19.1	19.7	18.4	18.6	18.9	19.1
12H	4H	18.6	18.9	19.1	19.3	19.8	18.6	18.9	19.1
6H	18.5	18.7	19.0	19.2	19.7	18.5	18.7	19.0	19.2
8H	18.5	18.7	19.0	19.1	19.7	18.4	18.6	19.0	19.1
Variations with the observer position at spacing:									
S =	1.0H	4.5 / -23.0				4.6 / -23.1			
	1.5H	6.1 / -24.6				6.2 / -24.6			
	2.0H	8.1 / -24.8				8.2 / -24.8			