

Coefficientes de uso

R	77	75	73	71	55	53	33	00	DRR
K0.8	77	73	70	68	72	70	69	67	78
1.0	80	77	74	72	76	74	73	71	83
1.5	84	81	79	78	80	79	78	75	89
2.0	87	85	83	82	84	82	81	79	93
2.5	88	87	86	85	86	85	84	81	96
3.0	89	88	88	87	87	86	85	83	98
4.0	90	90	89	89	88	88	87	84	99
5.0	91	90	90	90	89	89	87	85	100

Diagrama UGR

Corrected UGR values (at 440 lm bare lamp luminous flux)											
Reflect.:											
ceiling/cav		0.70	0.70	0.50	0.50	0.30	0.70	0.70	0.50	0.50	0.30
walls		0.50	0.30	0.50	0.30	0.30	0.50	0.30	0.50	0.30	0.30
work pl.		0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20	0.20
Room dim		viewed					viewed				
x	y	crosswise					endwise				
2H	2H	-2.8	-2.3	-2.6	-2.1	-1.8	-2.8	-2.3	-2.6	-2.1	-1.8
	3H	-3.0	-2.5	-2.7	-2.2	-1.9	-3.0	-2.5	-2.7	-2.2	-1.9
	4H	-3.0	-2.6	-2.7	-2.3	-2.0	-3.0	-2.6	-2.7	-2.3	-2.0
	6H	-3.1	-2.7	-2.8	-2.4	-2.1	-3.1	-2.7	-2.8	-2.4	-2.1
	8H	-3.2	-2.8	-2.8	-2.4	-2.1	-3.2	-2.8	-2.8	-2.4	-2.1
	12H	-3.2	-2.8	-2.8	-2.5	-2.1	-3.2	-2.8	-2.8	-2.5	-2.1
4H	2H	-3.0	-2.6	-2.7	-2.3	-2.0	-3.0	-2.6	-2.7	-2.3	-2.0
	3H	-3.2	-2.8	-2.8	-2.5	-2.1	-3.2	-2.8	-2.8	-2.5	-2.1
	4H	-3.3	-2.9	-2.9	-2.6	-2.2	-3.3	-2.9	-2.9	-2.6	-2.2
	6H	-3.4	-3.1	-2.9	-2.7	-2.3	-3.4	-3.1	-2.9	-2.7	-2.3
	8H	-3.4	-3.1	-3.0	-2.7	-2.3	-3.4	-3.1	-3.0	-2.7	-2.3
	12H	-3.5	-3.2	-3.0	-2.8	-2.3	-3.5	-3.2	-3.0	-2.8	-2.3
8H	4H	-3.4	-3.1	-3.0	-2.7	-2.3	-3.4	-3.1	-3.0	-2.7	-2.3
	6H	-3.5	-3.3	-3.0	-2.8	-2.4	-3.5	-3.3	-3.0	-2.8	-2.4
	8H	-3.6	-3.4	-3.1	-2.9	-2.4	-3.6	-3.4	-3.1	-2.9	-2.4
	12H	-3.6	-3.5	-3.1	-3.0	-2.5	-3.6	-3.5	-3.1	-3.0	-2.5
12H	4H	-3.5	-3.2	-3.0	-2.8	-2.3	-3.5	-3.2	-3.0	-2.8	-2.3
	6H	-3.6	-3.4	-3.1	-2.9	-2.4	-3.6	-3.4	-3.1	-2.9	-2.4
	8H	-3.6	-3.5	-3.1	-3.0	-2.5	-3.6	-3.5	-3.1	-3.0	-2.5
Variations with the observer position at spacing:											
S =	1.0H	0.9 / -25.5					0.9 / -25.5				
	1.5H	9.7 / -26.0					9.7 / -26.0				
	2.0H	11.7 / -26.8					11.7 / -26.8				